

INSPECTION CHECKLIST FOR A

Fire hose



NAME DATE LOCATION

Inspectors are to check all the items in the "ITEMS TO BE CHECKED" for their own safety and the safety of others.

Indicate whether each item is in a good condition (using a tick) or not (using a cross). Where irrelevant, write n/a in the COMMENTS section. Where no amount is specified, any present amount can be considered present.

ITEMS TO BE CHECKED	<input type="checkbox"/>	COMMENTS
LOCATION		
EASILY LOCATABLE VIA SAFETY SIGNS		
UNOBSTRUCTED		
CABINET		
GLAZING SECURE, CLEAR AND UNDAMAGED		
DOOR OPENS FULLY		
VALVES, NOZZLES, HOSE, etc. EASILY ACCESSIBLE		
STEEL HOSE RACK		
HOSE FOLDS PLACED CORRECTLY OVER PINS		
NOZZLE CLIP IN PLACE AND CORRECTLY CONTAINED		
(IF ONE-MAN) HOSE PROPERLY INSTALLED & RETAINED		
MANUFACTURE DATE VISIBLE AND LEGIBLE		
HOSE RACK WILL SWING OUT OF CABINET AT 90°		
ANGLE HOSE VALVE		
HANDWHEEL IS PROPER SIZE & ATTACHED TO VALVE		
WATER IS SUPPLIED TO VALVE WITH NO LEAKS		
FIRE HOSE		
COUPLERS, HOSE SECTION & LEAKERS UNDAMAGED		
CORRECT HOSE THREAD ADAPTERS PROVIDED		
MALE & FEMALE COUPLING THREADS UNDAMAGED		
CORRECT FEMALE COUPLING SWIVEL GASKET IN PLACE		
HOSE CONNECTED TO RACK NIPPLE		
HOSE IN GOOD GENERAL CONDITION		
HOSE RACK NIPPLE		
SECURELY ATTACHED TO ANGLE HOSE VALVE		
THREAD UNDAMAGED AND NIPPLE UNBLOCKED		
NOZZLE		
APPROPRIATE FOR THE MOST LIKELY FIRE TYPE		
NOZZLE GASKET IN PLACE & IN GOOD CONDITION		

*HMIS stands for Hazardous Material Identification System

FIRST AIDER SIGNATURE DATE

**Never rush an inspection.
Remember: your reputation is on the line!**

**A fire hose is only as effective as the person using it.
Contact us at +27 (0) 12 661 6721 or visit us at
www.hretd.co.za for quality in-service training**